



STRUCTURAL STABILITY CERTIFICATE

Subject- Structural Assessment report based on Visual Inspection of School Building (Shree Vashishtha Vidhyalaya) situated at Vav, N.H. No. 48, Tal. Kamrej, Dist. Surat, PIN code-394185 having blocks/floors as per below detail.

Details of blocks in school	Block A	Block B	Block C	Block D
No. of floors in the block	G+4	G+3	G+4	G+5
Age of building	2008	2015	2020	2025

With Reference to above, the building was visually inspected on date: 01/12/2025 in order to assess the structural condition and my observations and opinion are as below.

1. The School Building (Block A and B) was not designed by me and architectural drawings and Structural drawings are not available for review.
2. The structure is an R.C.C. framed building with brick infill walls. The terrace floor is covered with a fabricated M.S. dome. The structural stability assessment has been carried out for the R.C.C. building only.
3. **Structural distress or minor damages were not observed in structural members. Leakage and Seepage was not found at Terrace Floor and toilet blocks. There for the best of our knowledge, Experience and visual observation, the structure is safe to occupy under Normal gravity loading condition provided.**
4. This Stability Certificate given only for static loading condition (Dead load + Live load). This certificate shall not be valid in the event of structural collapse due to natural disasters.
5. To maintain the safety and structural adequacy of the building, loading condition and structural system shall not be changed/ altered in future and structure should be maintained properly. All present minor structural and non-structural cracks, leakage, seepage, effloresce, debonding of plaster, effective rainwater disposal etc needs to be attended earliest. Structure should be maintained properly and regularly to have no leakage or seepage. Also, Terrace / roof floor need to watertight and waterproof.
6. The structure needs to be get structurally audited every One Years for its structural safety and adequacy.

Tribhuvan Gedia

Gedia TDO/SEOR/600

CANOPUS ENGINEERING GROUP

Tribhuvan Gedia (M.Tech. Structure)

License No.: TDO/STDR/600

233, Golden Square, Near D-Mart,
Mota Varacha, Surat-394101

+91 8980 8980 85

233, Golden square, near D-mart,
mota varacha, surat-394101.

info@canopuseng.in

www.canopuseng.in